

**ENTERED**

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W054365

UNIQUE WELL I.D. #

Water Right Permit No. 30-3E-23E

(1) OWNER: Name Pebble Beach Water Address 3952 S.W. Camano Dr. Camano Is.

(2) LOCATION OF WELL: County Island SW 1/4 NW 1/4 Sec 23 T. 30 N. R. 3E WM.

(2a) STREET ADDRESS OF WELL (or nearest address) 3952 S.W. Camano Dr. Camano Is. wa 98292

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (If more than one) \_\_\_\_\_  
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 163 feet. Depth of completed well 160 ft.

(6) CONSTRUCTION DETAILS:  
Casing installed: 6 Diam. from 0 ft. to 155 ft.  
Welded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒  
Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐  
Manufacturer's Name Nakomo  
Type SS Model No. \_\_\_\_\_  
Diam. 5 Slot size 8 from 155 ft. to 160 ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 40' ft.  
Material used in seal Benlonite  
Did any strata contain unusable water? Yes ☐ No ☒  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name unknown  
Type: \_\_\_\_\_ H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.  
Static level 112 ft. below top of well Date 1-22-92  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made? Yes ☐ No ☐ If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "  
" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test \_\_\_\_\_  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Airstest 20 gal./min. with stem set at 159 ft. for 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Top soil	0	2
Hard pan	2	66
Grey clay	66	117
Brown clay	117	140
Brown sandy clay	140	155
Brown sand & water	155	160

RECEIVED

FEB 24 1992

DEPT OF ECOLOGY

I certify the construction of this well meets state and county codes

Don Ste <sup>1692</sup>

Work Started 1-21 19 92 Completed 1-22 19 92

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Stein well Drilling  
(PERSON, FIRM OR CORPORATION) (TYPE OR PRINT)

Address 620 N. Wiborg Ct. Camano Is.

(Signed) Don Ste License No. 1692  
(WELL DRILLER)

Contractor's Registration No. Stein W005540 Date 1-22 19 92

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.